DATASHEET - AZ-3-C125

Miniature circuit breaker (MCB), 125A, 3p, C-Char



Part no.	AZ-3-C125
	211811
EL Number	1601053
(Norway)	

General specifications	
Product name	Eaton Moeller series xEffect - AZ MCB
Part no.	AZ-3-C125
EAN	4015082118112
Product Length/Depth	90 millimetre
Product height	75 millimetre
Product width	81 millimetre
Product weight	0.658 kilogram
Compliances	RoHS conform
Certifications	IEC/EN 60947-2 EN45545-2 IEC 61373
Product Tradename	xEffect - AZ MCB
Product Type	МСВ
Product Sub Type	None
Delivery program	
Application	Switchgear for industrial and advanced commercial applications xEffect - Switchgear for industrial and advanced commercial applications
Number of poles	Three-pole
Number of poles (total)	3
Number of poles (protected)	3
Tripping characteristic	С
Release characteristic	С
Amperage Rating	125 A
Туре	AZ Miniature circuit breaker
Technical Data - Electrical	
Voltage type	AC
Voltage rating	230 V AC / 400 V AC
Voltage rating at DC	60 V DC (per pole)
Rated operational voltage (Ue) - max	400 V
Rated insulation voltage (Ui)	440 V
Rated impulse withstand voltage (Uimp)	4 kV
Frequency rating - min	50 Hz
Frequency rating - max	60 Hz
Rated switching capacity (IEC/EN 60947-2)	15 kA
Operational switching capacity	20 kA
Rated short-circuit breaking capacity (EN 60898) at 230 V	0 kA
Rated short-circuit breaking capacity (EN 60898) at 400 V	0 kA
Rated short-circuit breaking capacity (IEC 60947-2) at 230 V	15 kA
Rated short-circuit breaking capacity (IEC 60947-2) at 400 V	15 kA
Admissible back-up fuse - max	200 A gL/gG
Selectivity class	3
Lifespan, electrical	10000 operations
Overvoltage category	Ш
Pollution degree	2
Direction of incoming supply	As required
Technical Data - Mechanical	
Frame	45 mm

Wild in number of mutules spacing 1 5 Burlin- stells 7-10 m. Munifing with spacing 2 mm. Munifing with spacing 2 mm. Munifing with spacing 100 (bother thats) Degree of solescion 100 (bother thats) Degree of solescion 100 (bother thats) Conversable conductor rese social (bother thats) 2 mm² Terminal spacetion 2 mm² Design variaficant rese social (bother thats) 2 mm² Terminal spacetion 2 mm² Read spacetonic correct to spacetonic (bother thats) 2 mm² Read spacetonic correct to spacetonic (bother thats) 2 mm² Read spacetonic correct to spacetonic (bother thats) 2 mm² Read spacetonic correct to spacetonic (bother thats) 2 mm² Read spacetonic correct to spacetonic (bother thats) 2 mm² Read spacetonic correct to spacetonic (bother thats) 2 mm² Read spacetonic correct to spacetonic (bother thats) 2 mm²	Enclosure width	90 mm
Built-in deal 15 min Munitry subin 27 min Degree of protection 100 (protectime (main)) Conservation continuer cross section (solid core) - max 25 min ² Conservation continuer cross section (solid core) - max 25 min ² Conservation continuer cross section (solid core) - max 25 min ² Terminal report cort continuer 75 min Terminal report cort continuer 25 min ² Terminal report cort continuer 25 min ² Terminal report cort cont dependent 100 min ² Paring arching cont control dependent 100 min ² Report report dependent		
Macrialy with the pule 21 m. Macrialy with the pule 21 m. Macrialy with the pule 27 m. Macrialy with the pule 27 m. Depres of protection 100 for pulse of the puls		
Municipy width 27 m Municipy width 77 m Municipy width 76 phateral iff CPR (0716 Dingrow of protection 76 phateral iff CPR (0716 Perinsis its per bottom 76 phateral iff CPR (0716 Connectable conductor cross section (widt-cont) - max 76 phateral iff CPR (0716 Connectable conductor cross section (widt-cont) - max 78 phateral iff CPR (0716 Connectable conductor cross section (widt-widt) - max 78 phateral iff CPR (0716 Connectable conductor cross section (widt-widt) - max 78 phateral iff CPR (0716 Terminal cosponyclocation colse 78 phateral iff CPR (0716 Terminal cosponyclocatin colse	•	27 mm
Maximing Mathad Tap has zill ECEN 10715 Degree at protection Per borken field Degree at protection Per borken field Terminads (control construction construction bill cons) - min 25 mm² Connectable conductor construction bill cons) - min 25 mm² Connectable conductor construction bill cons) - min 25 mm² Connectable conductor construction bill cons) - min 25 mm² Connectable conductor construction bill cons) 25 mm² Connectable conductor construction bill cons) 25 mm² Terminad practice construction bill cons) 25 mm² Persion at copacity (construct construction bill) 26 mm² Persion at copacity (con		27 mm
Degree of presection P60 (when filted) Tarninels frap and bottom 25 mm² Connectable conductor consist acting food-core) - mm 25 mm² Connectable conductor consist acting food-core) - mm 25 mm² Connectable conductor consist acting food-core) - mm 25 mm² Connectable conductor consist acting food-core) - mm 25 mm² Connectable conductor consist acting food-core) - mm 25 mm² Connectable conductor consist acting food-core) - mm 25 mm² Connectable conductor consist acting food-core) - mm 25 mm² Tarninels bottom 25 mm² Tarninel protection 70 mm² Design vorification as port IEC/EN 61433 + tachnical data 00 W Rand regarind to normer despendent 00 W Rand regarind to normer despendent 00 W Nather operating regenerure - min 31 G Anihert operating regenerure - min 31 G Anihert operating regenerure - min Mest the product standord's requirements. 122.21 Wolf-action of resistence Mest the product standord's requirements. 122.21 Wolf-action of resistence Mest the product standord's requirements. 122.22 mm²	-	Top-hat rail IEC/EN 60715
Image Image Teamode jop and locood Citizenais Connectable conductor crass sector locid care) - nin S 25 mm ³ Connectable conductor crass sector locid care) - nin S 25 mm ³ Connectable conductor crass sector locid care) - nin S 25 mm ³ Connectable conductor crass sector locid-wated - max S 00 mm ³ Connectable conductor crass sector locid-wated - max S 00 mm ³ Terminal protection S 25 mm ³ 20 mm ³ Terminal protection S 00 mm ³ Rand operations a current fragotide has discipation in S 00 mm ³ Rand sequencing out, current-dependent S 00 W Equipments has dissipation, con-current-dependent S 00 W Design verification as per IEC/EN 6139 W 123.2 Verification of treatmal about protectabarder fragotime fra	-	
Connectable conductor cross section (solid coor) - max So mat Connectable conductor cross section (solid coor) - max So mat Connectable conductor cross section (solid coor) - max So mat Connectable conductor cross section (solid coor) - max So mat Connectable conductor cross section (solid coor) - max So mat Connectable conductor cross section (solid coor) - max So mat Terminel procession So mat Period procession		IP20
Connectable conductor cross section (null-wined) - max 25 mm ² 80 mm ² Connectable conductor cross section (null-wined) - max 25 mm ² 90 mm ² Terminal copulation cross section (null-wined) - max 25 mm ² 90 mm ² Terminal copulation cross section (null-wined) - max 25 mm ² 90 mm ² Terminal copulation cross section (null-wined) - max 75 mm ² 90 mm ² Read operational current for specified forst designation (null 75 A 75 A Nead issignation concurrent-dependent 90 W 90 W Static heat dissignation, concurrent-dependent 90 W 90 W Ambient operating issignature - min 75 C 90 W Ambient operating issignature - min 75 C 90 W Ambient operating issignature - min 75 C 90 W 19.2.3 Unification as por IEC/EN 61439 90 W 90 W 19.2.3 Unification as por itscification and materials to numb heat 76 C 90 W 19.2.3 Unification as aboreant heat/files proteinal beat to numb heat 76 C 90 Mm ² 19.2.3 Unification as aboreant heat/files proteinal beat obscification as requirements. 192 Minet heat distribution and materials to numb hea	Terminals (top and bottom)	
Connectable conductor cross section (mul-wired) - max So ma ² Terminal conductor cross section (mul-wired) - max So ma ² Terminal conductor So ma ² Terminal conductor So ma ² Terminal conductor So ma ² Design varification as por IEC/LN 81439 - technical data Disting varification as por IEC/LN 81439 - technical data Rated capacity control design varification as por IEC/LN 81439 - technical data Disting varification as por IEC/LN 81439 - technical data Rated capacity control design varification as por IEC/LN 81439 - technical data Disting varification as por IEC/LN 81439 - technical data Rated capacity control design varification as por IEC/LN 81439 - technical data Disting varification as por IEC/LN 81439 - technical data Rated capacity control design varification as por IEC/LN 81439 - technical data Disting varification as por IEC/LN 81439 - technical data Rated capacity control design varification as por IEC/LN 81439 - technical data Disting varification as por IEC/LN 81439 - technical data Rated capacity control design varification as por IEC/LN 81439 - technical data Disting varification as por IEC/LN 81439 - technical data Rated capacity control design varification as por IEC/LN 81439 - technical data Disting varification as por IEC/LN 81439 - technical data Rated capacity control design varification as por IEC/LN 81439 - technical data Disting varification as por IEC/LN 81439 - technical data Rated capacity data	Connectable conductor cross section (solid-core) - min	
Connectable conductor cross section (multi-wired) - max 50 mm ² Terminal copacity (cannot calable) Fager and hand took sele, 0500 VSS, EV 50224 Design verification as per IEC/EN 61439 - technical data 60 mm ² Read copacitional carcent or projection that designation (m) 15 A Hest dissipation per pole, current dependent 00 W Solid interface 00 W Solid interface 00 W Match displation, current dependent 00 W Ambert operating temperature - max 00 W Ambert operating temperature - max 00 W Design verification as per IEC/EN 61439 00 W 102.2.1 Verification as per IEC/EN 61439 00 W 102.2.2.1 Verification of Instant abouth battifts printeral electrification as per IEC/EN 61439 Meets the product standard's requirements. 102.2.2.1 Verification of restanting materina battifts printeral electrification as per IEC/EN 61439		
Terninal capatity (control cable) 25 mm ² - 30 mm ² Terninal protection Finger and hand touch safe, DEUV VS3, EN 5024 Design verification as per IEC/EN 51439 - technical data 0 W Read operations (current dependent 0 W Extine based sizes, how-current dependent 0 W State based sizes, how-current dependent 0 W Heat dissignation, capacity 0 W Ambent operating temperature - min -25 °C Anabent operating temperature - min -25 °C Design verification as per IEC/EN 51439	Connectable conductor cross section (multi-wired) - min	2.5 mm ²
Terminal particular Figure and land touch alle, DBUV VS3, EN 90274 Design verification as per IEC/EN 61439 - technical data Figure and land touch alle, DBUV VS3, EN 90274 Read dissipation product transformed pendent OW Equipment heat dissipation, current-dependent OW Static heat dissipation, current-dependent OW Equipment heat dissipation, current-dependent OW Rated dissipation report. current-dependent OW Rated dissipation, concurrent-dependent OW Rated	Connectable conductor cross section (multi-wired) - max	
Design verification as por IEC/EN 61439 - technical data ISA Read operational corrent for specified heat dissipation (n) ISA Heat dissipation per pole, current-dependent 000 Equipment theat dissipation, current dependent 000 Static heat dissipation, current dependent 000 Anabent operating temporature - max 000 Design verification as per IEC/EN 61439 Static heat dissipation, current dependent 102.2.1 Vorification of thermal stability of enclosures Static heat dissipation, current dependent 102.2.3 Vorification of thermal stability of enclosures Meets the product standard's requirements. 102.3.2 Vorification of thermal stability of enclosures Meets the product standard's requirements. 102.3.2 Vorification of resistance of insultating materials to normal heat Meets the product standard's requirements. 102.3.3 Vorification of resistance of insultating materials to normal heat Meets the product standard's requirements. 102.4 Meets the product standard's requirements. Desen dapply, since the enfine switchiger meeds to be evaluated. 102.5 Units Desen dapply, since the enfine switchiger meeds to be evaluated. 102.5 Units Desen dapply, since the enfine switchiger meeds to be evaluated. 102.5 Units Des		2.5 mm ² - 50 mm ²
Rated operational current for specified heat dissipation (in) ISS A Heat dissipation, per pole, current-dependent 0 W Equipment heat dissipation, current-dependent 0 W Static heat dissipation, current-dependent 0 W Heat dissipation, capacity 0 W Ambient operating temperature - min 0 W Ambient operating temperature - max 0 W Design verification as per LECK 61439 5° C 102.21 Orresion resistance Meets the product standard's requirements. 102.22 Verification of fesistance of insulating materials to normal heat Meets the product standard's requirements. 102.23 Resist of insul. max to absommal heat/file by internal elect. effects Meets the product standard's requirements. 102.24 Resistance to URV reduction (UV) reduction Meets the product standard's requirements. 102.24 Resistance to URV reduction Meets the product standard's requirements. 102.24 Resistance to URV reduction Meets the product standard's requirements. 102.25 Resistance to URV reduction Meets the product standard's requirements. 102.26 Meetancial inspect Meets the product standard's requirements. 102.27 Inscriptions Meets the product standard's requirements. 102.26 Meetancial inspect Des not		Finger and hand touch safe, DGUV VS3, EN 50274
Heat dissipation per pla, current-dependent DW Equipment hard dissipation, non-current-dependent S557 W Static heat dissipation, non-current-dependent DW Ambient operating temporature - max DW Ambient operating temporature - max S57 C Design verification as per IEC/EN 61439 Meets the product standard's requirements. 102.2.2 Orrison resistance Meets the product standard's requirements. 102.2.3 Verification of resistance of malufung materials to normal heat Meets the product standard's requirements. 102.2.4 Verification of resistance of malufung materials to normal heat Meets the product standard's requirements. 102.2.4 Verification of resistance of malufung materials to normal heat Meets the product standard's requirements. 102.2.4 Verification of assembles Meets the product standard's requirements. 102.2.4 Meets the product standard's requirements. Does not apply, since the entire switchgar needs to be evaluated. 102.5 Meets the product standard's requirements. Does not apply, since the entire switchgar needs to be evaluated. 102.6 Meets the product standard's requirements. Does not apply, since the entire switchgar needs to be evaluated. 102.7 Meets/maint evolution of assembles Does not apply, since the entire switchgar needs to be evaluated. 103.2 Meets and	Design verification as per IEC/EN 61439 - technical data	
Equipment heat dissipation, current-dependent 355 W State heat dissipation, current-dependent 0 W Heat dissipation, courrent-dependent 0 W Heat dissipation, courrent-dependent 0 W Ambient operating temperature - min 25 °C. Anbient operating temperature - max 55 °C Design verification as per IEC/EN 61439 Meets the product standard's requirements. 102.22 Verification of thermal stability of enclosures Meets the product standard's requirements. 102.23 Verification of thermal stability of enclosures Meets the product standard's requirements. 102.24 Verification of thermal stability of enclosures Meets the product standard's requirements. 102.25 Uring Oues not apply, since the entire switchger needs to be evaluated. 102.5 Iting Oues not apply, since the entire switchger needs to be evaluated. 102.6 Meets and creepage distances Meets the product standard's requirements. 103.0 Sproe of protection against electric is chrk. Does not apply, since the entire switchger needs to be evaluated. 10.4 Clearance and creepage distances Meets the product standard's requirements. 10.5 Derotion of assemblies Does not apply, since the entire switchger needs to be evaluated. 10.6 Clearance is or darmal conductors Meets t	Rated operational current for specified heat dissipation (In)	125 A
Static hear dissipation, non-current-dependent 0W Heat dissipation, non-current-dependent 0W Anbient operating temperature - min 25 °C Anbient operating temperature - max 0M Design verification as per IEC/EN 51439 55 °C 102.22 Corrasion resistance Mests the product standard's requirements. 102.3.1 Verification of trainating materials to normal heat Mests the product standard's requirements. 102.3.2 Verification of resistance of insulating materials to normal heat Mests the product standard's requirements. 102.3.2 Verification of trainating materials to normal heat Mests the product standard's requirements. 102.3.4 Verification of university of enclosures Mests the product standard's requirements. 102.4 Resist of resistance to ultra-violet UVI radiation Mests the product standard's requirements. 102.4 Resist of creating a grade distances Mests the product standard's requirements. 102.5 Lifting Des not apply, since the entire switchgear needs to be evaluated. 102.4 Resistor of assemblies Mests the product standard's requirements. 103.2 Breace d protection of assemblies Mests the product standard's requirements. 103.2 Breace d protection of assemblies Des not apply, since the entire switchgear n	Heat dissipation per pole, current-dependent	0 W
Heat dissipation capacity OW Ambinet operating temperature - min 25° C Design verification as por IEC/EN 61433 5° C 10.2.2 for soin resistance Meets the product standard's requirements. 10.2.2.2 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.2.2 Verification of insultanty materials to normal heat/fire by internal elect.effects Meets the product standard's requirements. 10.2.3.1 Verification of insultanty materials to normal heat/fire by internal elect.effects Meets the product standard's requirements. 10.2.2.4 Derivation of assemblies Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear meeds to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear meeds to be evaluated. 10.2.7 Nortection against electric shock Does not apply, since the entire switchgear meeds to be evaluated. 10.8 Connections for external conductors Meets the product standard's requirements. 10.9 Protection of switching devices and components Does not apply, since the entire switchgear meeds to be evaluated. 10.8 Connections for external conductors Meets the product standard's requirements. 10.8 Connections for external conductors Meets the product standard's requirements. 10.8 Connections for external conductors Meets the product standard's requirements. 10.	Equipment heat dissipation, current-dependent	35.67 W
Ambient operating temperature - max 5° C Design verification as per IEC/EN 61439 5° C 102.2 Corresion resistance Metes the product standard's requirements. 102.2.1 Verification of resistance Metes the product standard's requirements. 102.2.2 Verification of resistance Metes the product standard's requirements. 102.2.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects Metes the product standard's requirements. 102.2.4 Nortication of resistance Metes the product standard's requirements. 102.2.4 Nortication of assemblies Does not apply, since the enrice witchgear needs to be evaluated. 102.5 Inchanical impact Does not apply, since the enrice witchgear needs to be evaluated. 102.6 Mechanical impact Does not apply, since the enrice witchgear needs to be evaluated. 102.6 Mechanical impact Does not apply, since the enrice witchgear needs to be evaluated. 102.6 Mechanical impact Does not apply, since the enrice witchgear needs to be evaluated. 103.7 Internal electrical circuits and connections Metes the product standard's requirements. 103.6 Morecines for external conductors Is the panel builder's responsibility. 104.7 Internal electrical circuits and connections Is the panel builder's responsibility. 105.8 Morecines for external conductors	Static heat dissipation, non-current-dependent	0 W
Ambient operating temperature - max F5 °C Design verification as per IEC/EN 51439 Meets the product standard's requirements. 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3 I Verification of treins stability of enclosures Meets the product standard's requirements. 10.2.3 I Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.2.3 I Verification of utre-violet (UV) rediation Meets the product standard's requirements. 10.2.3 I Verification of treins in the interviolet (UV) rediation Does not apply, since the entire switchgear needs to be evaluated. 10.2.4 Resistance to ultre-violet (UV) rediation Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Inscriptions Does not apply, since the entire switchgear needs to be evaluated. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearance and creepse distances Does not apply, since the entire switchgear needs to be evaluated. 10.8 Connections for octornal conductors Is the panel builder's reaponsibility. 10.8 Connections for octornal conductors Is the panel builder's reaponsibil	Heat dissipation capacity	0 W
Design verification as per IEC/EN 61439 Meets the product standard's requirements. 102.2 Corrosion resistance Meets the product standard's requirements. 102.2.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 102.2.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 102.2.3 Resist of insul.mat to abnormal heat/line by internal elect. effects Meets the product standard's requirements. 102.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 102.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 102.7 Inscriptions Meets the product standard's requirements. 103.0 Regree of protection of assemblies Meets the product standard's requirements. 104.0 Roroporation of switching divices and components Meets the product standard's requirements. 104.0 Roroporation of switching divices and components Meets the product standard's requirements. 103.0 Roper-frequency electric strength Does not apply, since the entire switchgear needs to be evaluated. 104.0 Roroporation of switching divices and components Is the panel builder's responsibility. 103.0 Roper-frequency electric strength Is the panel builder's responsibility.	Ambient operating temperature - min	-25 °C
10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.23.3 Resist of insul. mat to abnormal heat/fire by internal elect effects Meets the product standard's requirements. 10.24 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.25 Urting Dees not apply, since the entire switchgear needs to be evaluated. 10.26 Mechanical impact Dees not apply, since the entire switchgear needs to be evaluated. 10.3 Degree of protection of assemblies Dees not apply, since the entire switchgear needs to be evaluated. 10.4 Derances and creegage distances Dees not apply, since the entire switchgear needs to be evaluated. 10.4 Derances and creegage distances Dees not apply, since the entire switchgear needs to be evaluated. 10.3 Degree of protection against electric shock Dees not apply, since the entire switchgear needs to be evaluated. 10.4 Derances and creegage distances Entire switchgear needs to be evaluated. 10.5 Incorportion of switching an aterial Dees not apply, since the entire switchgear needs to be evaluated. 10.6 Incorportion of switching an aterial Is the panel builder's responsibili	Ambient operating temperature - max	55 °C
102.1 Verification of themal stability of enclosures Meets the product standard's requirements. 102.2.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 102.3.3 Resist. of insul. mat. to abnormal heat/lire by internal elect. effects Meets the product standard's requirements. 102.4 Resistance to ultra-violat (UV) radiation Meets the product standard's requirements. 102.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 102.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 103.1 Geree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 104.1 Clearances and creepage distances Meets the product standard's requirements. 105.1 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 105.1 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 105.2 Protection against electric strongth Is the panel builder's responsibility. 105.2 Protection against electric strength Is the panel builder's responsibility. 105.2 Protection against electric strength Is the panel builder's responsibility. 105.2 Protection against electric strength Is the panel builder's responsibility. <t< td=""><td>Design verification as per IEC/EN 61439</td><td></td></t<>	Design verification as per IEC/EN 61439	
10.2.3.2 Verification of resistance of insulating materials to normal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Does not apply, since the entire switchgear needs to be evaluated. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Est the panel builder's responsibility. 10.8 Connections for external conductors Est the panel builder's responsibility. 10.9.2 Power-frequency electric strength Est the panel builder's responsibility. 10.9.3 Inpulse withstand voltage Is the panel builder's responsibility. 10.9.1 Temperature rise The panel builder's responsibility. 10.9.2 Temperature rise Is the panel builder's responsibility. 10.9.4 Testing of enclosures m	10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Does not apply, since the entire switchgear needs to be evaluated. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Does not apply, since the entire switchgear needs to be evaluated. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Est the panel builder's responsibility. 10.8 Connections for external conductors Est the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Est the panel builder's responsibility. 10.10 Temperature rise Est the panel builder's responsibility. 10.12 Electromagnetic compatibility Est the panel builder's responsibility. 10.13 Mechanical function Est the panel builder's responsibility. 10.13 Mechanical function	10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.24 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.26 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and crepage distances Meets the product standard's requirements. 10.5 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electric dircuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the	10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
102.5 LiftingDoes not apply, since the entire switchgear needs to be evaluated.102.6 Mechanical impactDoes not apply, since the entire switchgear needs to be evaluated.102.7 InscriptionsDoes not apply, since the entire switchgear needs to be evaluated.10.4 Clearances and creepage distancesDoes not apply, since the entire switchgear needs to be evaluated.10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.7 Internal electrical circuits and connectionsDoes not apply, since the entire switchgear needs to be evaluated.10.8 Connections for external conductorsIs the panel builder's responsibility.10.8.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionSAdditional informationSEurer timiting classSFeaturesAdditional equipment possibleSpecial featuresAdditional equipment possibleSpecial featuresAdditional equipment possible	10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements.
10.2.6 Mechanical impactDoes not apply, since the entire switchgear needs to be evaluated.10.2.7 InscriptionsMeets the product standard's requirements.10.3. Degree of protection of assembliesDoes not apply, since the entire switchgear needs to be evaluated.10.4 Clearances and creepage distancesMeets the product standard's requirements.10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Inpulse withstand voltageIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications in the instruction leaderAdditional informationIs the panel builder's responsibility. The specifications in the instruction leader<	10.2.4 Resistance to ultra-violet (UV) radiation	Meets the product standard's requirements.
10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function Is the panel builder's responsibility. The specifications for the switchgear must be observed.	10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.3 Degree of protection of assembliesDees not apply, since the entire switchgear needs to be evaluated.10.4 Clearances and creepage distancesMeets the product standard's requirements.10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must be observed.Additional eluftorationIs the panel builder's responsibility. The specifications for the switchgear must be observed.Additional functionIs the panel builder's responsibility. The specifications for the switchgear must be observed.Additional eluftersSpecial featuresSpecial featuresAdditional equipment possibleAdditional equipment possibleAdditional equipment possibleFeaturesAdditional equipment possible </td <td>10.2.6 Mechanical impact</td> <td>Does not apply, since the entire switchgear needs to be evaluated.</td>	10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distancesMeets the product standard's requirements.10.5 Protection against electric shockDoes not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchgear needs to be evaluated.10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionThe device meets the requirements, provided the information in the instruction leaflet (IL) is observed.Current limiting cless3FeaturesAdditional equipment possibleSpecial featuresAthient temperature hint: a 1 °C increase results in a 0.5% linear reduction of	10.2.7 Inscriptions	Meets the product standard's requirements.
10.5 Protection against electric shockDees not apply, since the entire switchgear needs to be evaluated.10.6 Incorporation of switching devices and componentsDees not apply, since the entire switchgear needs to be evaluated.10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must be observed.Additional informationIt device meets the requirements, provided the information in the instruction leafiet (IL) is observed.Current limiting class3FeaturesAdditional equipment possibleSpecial featuresAdditional equipment possible	10.3 Degree of protection of assemblies	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and componentsDoes not apply, since the entire switchigear needs to be evaluated.10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility. The specifications for the switchgear must be cobserved.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionThe device meets the requirements, provided the information in the instruction leaflet (IL) is observed.Additional informationSpecial featuresSpecial featuresAdditional equipment possible	10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.7 Internal electrical circuits and connectionsIs the panel builder's responsibility.10.8 Connections for external conductorsIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.14 Current limiting classIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.15 Special featuresIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.15 Special featuresIs the panel builder's responsibility. The sp	10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductorsIs the panel builder's responsibility.10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must be observed.Additional informationThe device meets the requirements, provided the information in the instruction refer to the device.Current limiting class3FeaturesAdditional equipment possibleSpecial featuresAmbient temperature hint: a 1 °C increase results in a 0.5% linear reduction of	10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.9.2 Power-frequency electric strengthIs the panel builder's responsibility.10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must be observed.Additional informationIt device meets the requirements, provided the information in the instruction It device meets the requirements, provided the information in the instruction Is observed.Current limiting class3FeaturesAdditional equipment possibleSpecial featuresAdditional equipment possibleSpecial featuresAthien at "C increase results in a 05% linear reduction of the subscinear of the subsci	10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltageIs the panel builder's responsibility.10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.10 Temperature riseIs the panel builder's responsibility.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must be observed.Additional informationIt ease FeaturesSpecial featuresAdditional equipment possibleSpecial featuresAdditional equipment possible	10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.10.10 Temperature riseThe panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionIs the panel builder's responsibility. The specifications for the switchgear must be observed.Additional informationIs the panel builder's responsibility. The specifications for the switchgear observed.Current limiting classIs the panel builder's responsibility. The specifications for the switchgear observed.FeaturesAdditional equipment possibleSpecial featuresAdditional equipment possible	10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.10 Temperature riseThe panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionThe device meets the requirements, provided the information in the instruction leaflet (IL) is observed.Additional informationYet the device meets the requirements, provided the information in the instruction leaflet (IL) is observed.Features3Special featuresAdditional equipment possible Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of		Is the panel builder's responsibility.
InterpretationProvide heat dissipation data for the devices.10.11 Short-circuit ratingIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.12 Electromagnetic compatibilityIs the panel builder's responsibility. The specifications for the switchgear must be observed.10.13 Mechanical functionInterpretationAdditional informationInterpretationCurrent limiting classInterpretationFeaturesSpecial featuresSpecial featuresAdditional equipment possibleAdditional equipment possibleAdditional equipment possible	10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.12 Electromagnetic compatibility observed. 10.13 Mechanical function Image: Compatibility of the section of the sectio	10.10 Temperature rise	
10.13 Mechanical function Image: Constraint of the con	10.11 Short-circuit rating	
Additional information Image: Current limiting class Image: Current limiting class Image: Current limiting class Features 3 Special features Additional equipment possible Special features Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of	10.12 Electromagnetic compatibility	
Current limiting class 3 Features Additional equipment possible Special features Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of	10.13 Mechanical function	
Features Additional equipment possible Special features Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of		
Special features Ambient temperature hint: a 1 °C increase results in a 0.5% linear reduction of		
	Features	
	Special features	
Used with Miniature circuit breaker AZ	Used with	

Technical data ETIM 9.0

Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)		
Electric engineering, automation, process control engineering / Electrical installation, [AAB905019])	device / Miniature ci	rcuit breaker system (MCB) / Miniature circuit breaker (MCB) (ecl@ss13-27-14-19-01
Built-in depth	mm	75
Release characteristic		C
Number of poles (total)		3
Number of protected poles		3
Rated current	А	125
Rated voltage	V	400
Rated insulation voltage Ui	v	440
Rated impulse withstand voltage Uimp	kV	4
Rated short-circuit breaking capacity Icn according to EN 60898 at 230 V	kA	0
Voltage type		AC
Rated short-circuit breaking capacity Icn according to EN 60898 at 400 V	kA	0
Rated short-circuit breaking capacity Icu according to IEC 60947-2 at 230 V	kA	15
Rated short-circuit breaking capacity Icu according to IEC 60947-2 at 400 V	kA	15
Frequency	Hz	50 - 60
Power loss	W	
Current limiting class		3
Flush-mounted installation		No
Concurrently switching neutral conductor		No
Over voltage category		3
Pollution degree		2
Additional equipment possible		Yes
Width in number of modular spacings		4.5
Degree of protection (IP)		IP20
Ambient temperature during operating	°C	-25 - 55
Connectable conductor cross section multi-wired	mm ²	2.5 - 50
Connectable conductor cross section solid-core	mm ²	2.5 - 50
Explosion-proof		No